Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No: 01 Dated: 23/09/2026

It is certified that an inspection team headed by B. Anil Chandra Puneta, AE, RWS&S (Name of Officers with designation) from Gospadu RWS & S Inspected **SRI GURU RAJA EM SCHOOL, H.NO.8/252, MAIN ROAD, BABANAGAR, DEEBAGUNTLA (V), GOSPADU (M) NANDYAL DISTRICT, ANDHRA PRADESH.** (Name & Address of the school) on 19/09/2026 (date of inspection), and on the basis of Water Test Report (Attached) bearing no 01 dated 22/09/26 of N.D.M. Lab Nandyal (RWS & S Lab) certified that The **SRI GURU RAJA EM SCHOOL, H.NO.8/252, MAIN ROAD, BABANAGAR, DEEBAGUNTLA (V), GOSPADU (M) NANDYAL DISTRICT, ANDHRA PRADESH.** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 21/03/2027

Signature with Seal: 23/09/2026

Name: B. Anil Chandra Puneta

Designation: Assistant Engineer

Name & Address of the Office / Department: Assistant Engineer RWS & S Section Gospadu (M), Nandyal (Dt.)

To

SRI GURU RAJA EM SCHOOL,
H.NO.8/252, MAIN ROAD, BABANAGAR, DEEBAGUNTLA (V),
GOSPADU (M) NANDYAL DISTRICT,
ANDHRA PRADESH.

GOVERNMENT OF ANDHRA PRADESH

RURAL WATER SUPPLY AND SANITATION DEPARTMENT

REPORT ON CHEMICAL ANALYSIS OF WATER (DRINKING) GENARAL (PHYSICO - CHEMICAL PARAMETERS)

SI. NO	NAME OF THE MANDAL	NAME OF THE G.P	Habitation	LOCATION	DATE Of COLLECTION	TYPE OF SOURCE	Colour	TURBIDITY (N.T.U.Scale)	pH value	ELECTRICAL CONDUCTIVITY	TOTAL DISSOLVED SOLIDS (mg/lit)	CHEMICAL CHARECTERISTICS (Results Expressed in mg./liter									
												TOTAL ALKALINITY (as caco3)	TOTAL HARDNESS (as caco3)	CALCIUM HARDNESS (as ca2+)	MAGNESIUM HARDNESS (as Mg2+)	CHLORIDES (as Cl)	FLUOUORIDE (as F^-)	NITRATE (as No_3^-)	Sulphate ($So4^{-2}$)	IRON (as Fe)	REMARKS
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
PERMISSIBLE STANDARDS OF PHYSICAL AND CHEMICAL QUALITY (as per indian standard driniking water -specification IS 10500 : 2012)							5.0 to 15.0	1.0 to 5.0	6.50 to 8.50	-	500 to 2000	200 to 600	200 to 600	75 to 200	30 to 100	250 to 1000	1.0 to 1.5	45	200 to 400	1.0	Satisfactory/ Not Satisfactory
1	GOSPADU	Deebaguntla	Baba nagar	Sri Guru Raja E.M.School (H.No-8/252)Main Road	22/09/2026	Bore	Agreable	0.2	7.01	1366	888	240	380	77	45	298	0.42	3.8	25	0.04	Satisfactory

Remarks:- The Above Water Sample is Phisically and Chemically Satisfactory

Chemist
WQM Laboratory
NANDYAL
25/9/26

GOVERNMENT OF ANDHRA PRADESH

RURAL WATER SUPPLY & SANITATION

REPORT ON BACTERIOLOGICAL ANALYSIS OF WATER (DRINKING)

Sl. No	Date of Collection	Mandal	G.P	Habitation	Source code / location	Type of Source	Total coliform bacteria	Thermo Tolerant coliform bacteria / E.Coli	Residual Free Chlorine	Remarks
1	22/09/2026	GOSPADU	Deebaguntla	Baba nagar	Sri Guru Raja E.M.School (H.No-8/252)Main Road	Bore	0	0	Nill	SAFE

Remarks:- **The above Water Sample is Bacteriologically Safe**

K. Revathi 25/09/26

Lab Microbiologist

WQM Division Lab

Nandyal

GOVERNMENT OF ANDHRA PRADESH
RURAL WATER SUPPLY & SANITATION DEPARTMENT,
STATE LEVEL WATER TESTING LABORATORY
O/o THE PROJECT DIRECTOR
STATE WATER SANITATION MISSION
"C" BLOCK, VASUDHA SHALTERS, LIC COLONY, GOLLAPUDI, VIJAYAWADA – 521225.

RECEIPT

Date :

Receipt no. : 01

Amount Received: Rs. 1600/- (Rupees Sixteen Hundred Rupees only

Paid by Cash / Cheque / Demand Draft/ other mode :

Received from: Sri Guru Raja E.M School / Babanagar / Dcebaguntla(V) / Gospadu(M)

Towards the testing charges of Water (Drinking) Samples : Both chemical & Bacteriological - Tests

Amount Received By: WQM Laboratory, Nandyal.

Authorized Signature

Chemist
WQM Laboratory
NANDYAL